


TEMP CONST POWER THROUGH MAIN ELECTRICAL BUILDING SERVICE FOR SINGLE FAMILY DWELLINGS

Note 5.



1. FRAMING SUPPORTS MUST BE 2-1/2" ANGLE IRON, OR 1-5/8" X 3-5/8" 16 GA. STEEL STUDS EMBEDDED IN CONCRETE, OR 2"X4" PRESSURE TREATED LUMBER ANCHORED INTO RECTANGULAR STEEL BASES. THE SERVICE PANEL IS TO BE SECURED PER MANUFACTURERS INSTRUCTIONS.
2. ALL RECEPTACLES FOR CONSTRUCTION POWER SHALL BE GFCI PROTECTED PER ARTICLE 500 AND MUST BE RIGIDLY ATTACHED TO THE STRUCTURE OR SERVICE EQUIPMENT.
3. THE GROUNDING ELECTRODE IS TO BE MOUNTED IN THE SAME BAY AS THE SERVICE. THE GROUNDING ELECTRODE IS TO BE SIZED PER NEC AND IS TO BE INSTALLED PER ARTICLE 250 OF NEC.
4. THE ADDRESS IS TO BE POSTED ON THE SERVICE FOR THE INSPECTION.
5. LOCATE THE METER 4 FT MIN. AND 6 FT 3" MAX. ABOVE FINISHED GRADE.
6. TEMPORARY WEATHERPROOFING SHALL BE PROVIDED TO PROTECT ELECTRICAL EQUIPMENT FROM RAIN OR WINDBORNE SAND.